

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHEZ/771

Dated: 23/10/2025

It is certified that an inspection team headed by The Assistant Executive Engineer

(Name of Officers with designation) from Jal Shakti Department PHED

inspected the Deep Tubewell at IDPS Nagbal Shobian

(Name & Address of the school) on 20-05-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PHEZ/LAB/03 dated 28-05-2025

of Water Testing Lab. Zainapora (PHED Lab) certified that the


I.D.P.S. Nagbal Shobian (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 21.10.2026

Signature with Seal: 

Name

IMTIYAZ AHMAD MIR

Designation

Asst. Ex. Engineer, E.

Name & Address of the Office (Department)

Jal Shakti Department, PHE, S.B.

Sub Div. Zainapora Zainapora

To Principal IDPS

Nagbal Shobian

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Office. Of The Sub-Divisional Water Testing
Laboratory Zainapora

W.S.S:- Deep Tubewell

Source:- Deep Tubewell at I.D.P.S. Institute Nagbal Shopian

Date of Analysis:- 26-05-2025 to 27-05-2025

S.NO.	Parameters	Permissible Range	Result
01	Turbidity	Upto 10 NTU	7.8 NTU
02	pH	6.5 - 8.5	7.5
03	R. Chlorine	0.2 mg/l	0 mg/l
04	Iron	Upto 1.0 mg/l	0.1 mg/l
05	Total Hardness	Upto 600 mg/l	215 mg/l
06	Nitrate	Upto 45 mg/l	13 mg/l
07	Fluoride	Upto 1.0 mg/l	0.1 mg/l
08	Conductivity	Upto 800 μ S	632.8 μ S
09	T.D.S	Upto 2000 mg/l	316.4 mg/l
10	Coliform	Less than 10 MPN	Absent
11	Odour	Agreeable	Agreeable
12	Taste	Unobjectionable	Unobjectionable

Remarks:- Water is fit for drinking Purposes for the above mentioned Parameters.

No:- PHEZ/LAB/03

Date:- 28-05-2025

